

# Kitemark™ Certificate

This is to certify that:

Ogniochron S.A.  
Przemysłowa 42  
Andrychów  
34-120  
Poland

Holds Certificate Number:

KM 640707

In respect of:

**BS EN 3**  
**Portable fire extinguishers**

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

For and on behalf of BSI:

Shahm Barhom, Group Product Certification Director

First Issued: 2016-02-05

Latest Issue: 2024-04-09

Effective Date: 2024-04-09

Expiry Date: 2025-01-19

Page: 1 of 6



# Kitemark™ Certificate

No. KM 640707

Model No	Description	GA Drawing Reference, Revision & Date	Technical File Review
GP-1x ABC/M	1 kg ABC powder (FUREX ONE), stored pressure. Temperature range: -30 °C to 60 °C Average discharge duration: 6.8 s Working pressure at 20°C: 12 bar Fire rating: 8A and 34B	GAD Drawing Reference, Revision & Date: GP1-310-00-UK dated 2021-06-25	3166448
GP-1z BC/M	1 kg BC powder (FUREX BCE 20), cartridge operated (12g CO <sup>2</sup> ). Temperature range: -30 °C to 60 °C Average discharge duration: 6.5 s Fire rating: 21B	GAD Drawing Reference, Revision & Date: GP-1-330-00-UK dated 2023-05-18	3887312
GP-2x ABC	2 kg ABC powder (FUREX Pro), stored pressure. Temperature range: -30 °C to 60 °C Average discharge duration: 10 s Working pressure at 20°C: 12 bar Fire rating: 13A and 89B	GAD Drawing Reference, Revision & Date: GP2-100-00-UK dated 2021-06-25	3071692
GP-6x ABC/MP	6 kg ABC powder (FUREX S ABC), stored pressure. Temperature range: -30 °C to 60 °C Average discharge duration: 20.6 s Working pressure at 20°C: 15 bar Fire rating: 43A and 233B	GAD Drawing Reference, Revision & Date: GP-056-00-UK dated 2021-06-25	8409837

All the above products are certified to BS EN 3-7:2004+A1:2007

First Issued: 2016-02-05

Latest Issue: 2024-04-09

Effective Date: 2024-04-09

Expiry Date: 2025-01-19

Page: 2 of 6

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

# Kitemark™ Certificate

No. KM 640707

Model No	Description	GA Drawing Reference, Revision & Date	Technical File Review
GP-9x ABC/MP	9 kg ABC powder (FUREX S ABC), stored pressure. Temperature range: -30 °C to 60 °C Average discharge duration: 29.9 s Working pressure at 20°C: 15 bar Fire rating: 55A and 233B	GAD Drawing Reference, Revision & Date: GP9-40-00 dated 2021-06-24	8409837
GPN-3x AB/FF	3 litre foam (RÜHL FFX 150), stored pressure. Temperature range: 5°C to 60°C Working pressure at 20°C: 15 bar Average discharge duration: 30.21 s Fire rating: 13A	GAD Drawing Reference, Revision & Date: GPN3-050-00-UK dated 2023-04-28	3829751
GPN-6x AB	6 litre foam (5.91 litre water + 0.07 litre RÜHL AFFF COMPACT), stored pressure. Temperature range: 5 °C to 60 °C Average discharge duration: 47.8 s Working pressure at 20°C: 15 bar Fire rating: 21A and 183B	GAD Drawing Reference, Revision & Date: GPN6-100-00-UK dated 2021-06-24	3294804 and 3887312
GPN-6x AB/MP PLUS	6 litre foam (5.61 litre water + 0.3 litre FUREX A + 0.09 litre FUREX AFFF Kartusche), stored pressure. Temperature range: 5 °C to 60 °C Average discharge duration: 40.5 s Working pressure at 20°C: 15 bar Fire rating: 27A and 183B	GAD Drawing Reference, Revision & Date: GPN6-080-00-UK dated 2021-06-24	3368204 and 3887312

All the above products are certified to BS EN 3-7:2004+A1:2007

First Issued: 2016-02-05

Latest Issue: 2024-04-09

Effective Date: 2024-04-09

Expiry Date: 2025-01-19

Page: 3 of 6

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

# Kitemark™ Certificate

No. KM 640707

Model No	Description	GA Drawing Reference, Revision & Date	Technical File Review
GPN-6x AB/FF	6 litre foam (RÜHL FFX 150), stored pressure. Temperature range: 0°C to 60°C Working pressure at 20°C: 15 bar Average discharge duration: 49.6 s Fire rating: 27A and 144B	GAD Drawing Reference, Revision & Date: GPN6-130-00-UK dated 2023-05-04	3829751
GPN-6x ABF/ZENOVA	6 litre, foam (ZENOVA FX 12.1), stored pressure. Temperature range: 5°C to 60°C Working pressure at 20°C: 15 bar Average discharge duration: 35.1 - 40.1 s Fire rating: 34A, 113B and 75F	GAD Drawing Reference, Revision & Date: GPN6-140-00-UK dated 2022-05-23	30104609
GPN-9x AB/MP	9 litre foam (8.86 litre water + 0.14 litre FUREX AFFF Kartusche), stored pressure. Temperature range: 5 °C to 60 °C Working pressure at 20°C: 15 bar Average discharge duration: 69.4 s Fire rating: 27A and 233B	GAD Drawing Reference, Revision & Date: GPN9-50-00-UK dated 2021-06-24	8409837 and 3887312
GPN-9x AB/FF	9 litre foam (RÜHL FFX 150), stored pressure. Temperature range: 0°C to 60°C Working pressure at 20°C: 15 bar Average discharge duration: 65 s Fire ratings: 34A and 183B	GAD Drawing Reference, Revision & Date: GPN9-60-00-UK dated 2023-04-27	3829751

All the above products are certified to BS EN 3-7:2004+A1:2007

First Issued: 2016-02-05

Latest Issue: 2024-04-09

Effective Date: 2024-04-09

Expiry Date: 2025-01-19

Page: 4 of 6

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.  
A member of BSI Group of Companies.

# Kitemark™ Certificate

No. KM 640707

Model No	Description	GA Drawing Reference, Revision & Date	Technical File Review
GPN-9x ABF/ZENOVA	9 litre foam (ZENOVA FX 12.1), stored pressure. Temperature range: 5°C to 60°C Working pressure at 20°C: 15 bar Average discharge duration: 45.3 - 47.1 s Fire rating: 43A, 183B and 75F	GAD Drawing Reference, Revision & Date: GPN9-70-00-UK dated 2023-05-23	30104609
GW-6x A/MP	6 litre water, stored pressure. Temperature range: 5 °C to 60 °C Working pressure at 20°C: 15 bar Average discharge duration: 44.4 s Fire rating: 13A	GAD Drawing Reference, Revision & Date: GW6-030-00-UK dated 2021-06-23	8409837, 3294804 and 3887312
GWM-6x AF/MP	6 litre water, stored pressure. Temperature range: 5 °C to 60 °C Working pressure at 20°C: 15 bar Average discharge duration: 53.11 s Fire ratings: 13A and 40F	GAD Drawing Reference, Revision & Date: GWM6-020-00-UK dated 26/06/2021	3403082 and 3887312
GW-9x A/MP	9 litre water, stored pressure. Temperature range: 5 °C to 60 °C Working pressure at 20°C: 15 bar Average discharge duration: 52.2 s Fire rating: 21A	GAD Drawing Reference, Revision & Date: GW9-10-00-UK dated 2021-06-23	3403082 and 3887312

All the above products are certified to BS EN 3-7:2004+A1:2007

First Issued: 2016-02-05

Latest Issue: 2024-04-09

Effective Date: 2024-04-09

Expiry Date: 2025-01-19

Page: 5 of 6

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.  
A member of BSI Group of Companies.

# Kitemark™ Certificate

No. KM 640707

## **Suitability for li-ion fire types is outside the scope of this certification**

The above portable fire extinguisher models falling within the scope of this certificate may be marketed under the following brand names:

Ogniochron  
Commander  
Fire-Bull  
Streetwize  
Silverhook  
Firechief  
PJ Fire  
Blackwood



First Issued: 2016-02-05  
Latest Issue: 2024-04-09

Effective Date: 2024-04-09  
Expiry Date: 2025-01-19

Page: 6 of 6

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.  
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.  
A member of BSI Group of Companies.